From: Mike Bisagno
To: Jenah Thornborrow
Subject: RE: [External] SUBFY2021-0010
Date: Wednesday, July 13, 2022 2:50:20 PM
Attachments: image008.png
image009.png
image010.png
image011.png

Jenah,

The Boise Fire comments were just given as a list of requirements to follow. I did not mean for them to be construed as corrections required if not needed. As per the drawings, the fire access road is less than 150', so no turnaround would be required. If the developer is choosing to provide a turnaround, the specifications to be used are those in Appendix D of the 2018 International Fire Code. I hope this is the information you needed. If not, please feel free to call me with any questions or concerns.

Mike Bisagno
Division Chief - Fire Marshal
Boise Fire Department
Office: (208)570-6573
mbisagno@cityofboise.org

Creating a city for everyone.

From: Jenah Thornborrow <jthorn@GARDENCITYIDAHO.ORG>
Sent: Wednesday, July 13, 2022 12:53 PM
To: Mike Bisagno <MBisagno@cityofboise.org>
Subject: [External] SUBFY2021-0010

Mike,

I am writing you regarding a subdivision that you have reviewed. The subdivision is still going through the entitlement process. I am hoping that you might be able to provide some clarity for the record.

I am presuming that the Fire Department can accommodate a lack of hammerhead because the dead-end terminus is less than 150'. If this is correct, could you please confirm this?

Secondarily, the applicant has submitted the attached potential rendering showing a hammerhead, the document titled PETRA-POINT-PLAT-turnaround 07112022. Might you have any additional comments on this design? I have included a landscape plan to show the change, the document

titled Landscape Plan 06242022.

Thank you for your assistance.

Jenah E. Thornborrow

Director

Development Services Department, **City of Garden City**

p: 208-472-2921

a: 6015 Glenwood Street, Garden City, ID 83714

w: https://gardencityidaho.org/

Total Control Panel Login

To: jthorn@gardencityidaho.org Remove this sender from my allow list

From:
mbisagno@cityofboise.org

You received this message because the sender is on your allow list.