

Jeff Ramey
Commissioner/Chairman

J. Todd Bunderson
Commissioner

Jeff Souza
Commissioner



Shelley Vaughan
*District
Administrator*

April 22, 2024

Garden City Development Services

Re: DSRFY2024-0005 9655 W State St

These are design review comments for the construction of three portable classroom buildings on a site with an existing church.

The Boise Fire Department has reviewed and can approve the application subject to compliance with all the following code requirements and conditions of approval. Any deviation from this plan is subject to Fire Department approval. Please note that unless stated otherwise, this memo represents the requirements of the International Fire Code (IFC) as adopted and amended by the North Ada County Fire District.

Comments:

1. Fire hydrants, capable of producing the required fire flow, shall be located so that no part of the structure is more than 600-feet from the hydrant. (IFC 507.3, IFC B104, IFC B105, IFC C105).
2. Permits will need to be obtained for fire alarm installation and fire sprinkler installation (if required). These must be applied for with the City of Boise at the following link: <https://www.cityofboise.org/departments/planning-and-development-services/building/building-permits/?category=fire%20plan%20review%20-%20600&search=all>

General Requirement:

Fire Department required fire hydrants, access, and street identification shall be installed prior to construction or storage of combustible materials on site. Provisions may be made for temporary access and identification measures.

Specific building construction requirements of the International Building Code, International Fire Code and NACFR Rules will apply. However, these provisions are best addressed by a licensed Architect at time of building permit application.

Regards,

Mike Bisagno

Mike Bisagno
Division Chief – Fire Marshal
Boise Fire Department