

Jeff Ramey  
*Commissioner/Chairman*

J. Todd Bunderson  
*Commissioner*

Jeff Souza  
*Commissioner*



Shelley Vaughan  
*District  
Administrator*

June 12, 2023

Garden City Development Services

Re: CUPFY2023-0008 9297-9301 & 9251-9287 W State St

This is a conditional use permit request to use this property for office spaces that have both man doors and overhead doors fronting each condo.

The Boise Fire Department has reviewed this application and can approve of this conditional use with the suggestion that fire sprinklers be installed throughout these buildings for future uses as these condos are large enough and have access for fueled vehicles to be moved inside of each occupancy.

General Requirement:

Specific building construction requirements of the International Building Code, International Fire Code and NACFR Rules will apply. However, these provisions are best addressed by a licensed Architect at time of building permit application.

Regards,

*Mike Bisagno*

Mike Bisagno  
Division Chief – Fire Marshal  
Boise Fire Department