

Jeff Ramey
Commissioner/Chairman

J. Todd Bunderson
Commissioner

Jeff Souza
Commissioner



Shelley Vaughan
*District
Administrator*

June 27, 2024

Garden City Development Services

Re: DSRFY2024-0011 508 E 40th St

These are design review comments for the construction of one public parking lot at grade.

The Boise Fire Department has reviewed and can approve the application subject to compliance with all the following code requirements and conditions of approval. Any deviation from this plan is subject to Fire Department approval. Please note that unless stated otherwise, this memo represents the requirements of the International Fire Code (IFC) as adopted and amended by the North Ada County Fire District.

Comments:

The required inside turning radius for fire department access is 28'. The required outside turning radius is 48'. Please make the appropriate changes for fire department access.

General Requirement:

Fire Department required fire hydrants, access, and street identification shall be installed prior to construction or storage of combustibile materials on site. Provisions may be made for temporary access and identification measures.

Specific building construction requirements of the International Building Code, International Fire Code and NACFR Rules will apply. However, these provisions are best addressed by a licensed Architect at time of building permit application.

Regards,

Mike Bisagno

Mike Bisagno
Division Chief – Fire Marshal
Boise Fire Department