



**NORTH ADA COUNTY**  
**Fire & Rescue District**

Jeffrey A. Ramey  
*Commissioner/Chair*

J. Todd Bunderson  
*Commissioner*

Jeffrey A. Souza  
*Commissioner*

Shelley Young  
*District  
Administrator*

July 30, 2021

Garden City Development Services - Planning

Re: CUPFY2021-0012

This application is for CUP approval for a warehouse in an existing building with a current use of Office/Fabrication.

The North Ada County Fire & Rescue has reviewed and can approve the application subject to compliance with all the following code requirements and conditions of approval. Any deviation from this plan is subject to Fire Department approval. Please note that unless stated otherwise, this memo represents the requirements of the International Fire Code (IFC) as adopted and amended by NACFR Rules.

*Comments:*

1. This is for CUP approval, not an approval of a Certificate of Occupancy. A building permit would be required for a change of use.
2. Any High-piled Storage, (which is storage heights over 12' for common combustible materials, or over 6' for plastic materials) shall be in accordance with IBC 413 and IFC Chapter 32.

Regards,

*Mike Bisagno*

Mike Bisagno  
Division Chief – Fire Marshal  
Boise Fire Department