



## **CENTURION | B&A ENGINEERS, INC.**

Consulting Engineers and Land Surveyors  
2323 S. Vista Ave, Ste 206, Boise, ID 83705  
Telephone 208.343.3381 | [www.centengr.com](http://www.centengr.com)



To: **Garden City Planning**

Copy: **Jenah Thornborrow  
Betty Gumm  
Hanna Veal  
Colin Schmidt  
Kevin Wallis  
James Pavelek  
Troy Vaughn  
Chad Vaughn  
Olesya Durfey  
Kena Champion  
Building**

From: **Joe Canning, PE/PLS**  
Telephone: 208.343.3381  
E-Mail: [jdcanning@centengr.com](mailto:jdcanning@centengr.com)

Date: 20 August 2022

Subject: **The Sonder – Mixed Use  
210 East 35<sup>th</sup> Street  
DSRFY2022-0014  
Tax Parcel R2734540260  
Land Area = 0.28 Acres**

Pages: 3

Media: Transmitted via E-mail

On behalf of Garden City, as the city engineer, we have completed a review of the application for the subject project. This project is a mixed-use of the site.

Any approval of the project should be conditioned upon successfully addressing items presented in this review.

### ***Erosion and Sediment Control***

Prior to performing any grading on the site, the applicant must prepare and have approved by the city an erosion and sediment control plan.

### ***Ada County Highway District***

Approval of the project by the Ada County Highway District will be required.

### ***Fire District Approval***

Approval of the project by the North Ada County Fire and Rescue District will be required. Should fire flow requirements exceed those available, the land use, improvement of off-site city water lines or other efforts may be necessary to obtain approval of plans.

The review by the District will need to include review of locations of fire hydrants.

### ***Water and Sewer Connections***

New water and sewer services must be reviewed and approved by the city's Public Works Department.

The applicant is responsible to verify that adequate water system supply is available to provide any fire suppression water needs.

The applicant is responsible to confirm/verify that adequate sewer capacity is available and that the existing system depth is adequate to serve the site.

### ***Site Grading and Drainage Plan***

A site grading and drainage plan will be required. Said plan must be reviewed and approved by the city.

A storm water design report and a drainage system operation and maintenance manual for handling of storm water prepared by an Idaho licensed design professional will be required. Compliance with the storm water ordinance and policies of the city will be required. Drainage must be maintained on-site.

A site geotechnical report will be required for the design of the on-site storm water system prepared by a qualified license professional. Said report must identify the depth to seasonal high groundwater, provide a profile of encountered soils and their infiltration rates. The report also must provide a design infiltration rate recommendation for the storm water system. The storm water design must provide for at least three feet of vertical separation between the bottom of the storm water facility and the seasonal high groundwater.

### ***Storm Water Operation and Management Agreement***

The landowner must enter into an agreement with the city that will be recorded addressing mandatory maintenance of the site's storm water system. The agreement must be fully executed, have conditionally approved plans attached and be recorded by the city with final plan approval.

***FEMA Flood Maps***

The applicant should review the original FEMA work maps (not the current adopted maps) as the city has been placed in seclusion. The current maps (June 2020) do not display the possible future risk of the flooding potential of the Boise River. If the lowest floor building elevation is below the draft map BFE, a Flood Risk Acknowledgement form will be required from the landowner/developer.

***Parcel***

The project includes two lots of record. Please note that depending on the location of the existing lot line between the lots and the location of proposed buildings, a parcel consolidation survey, combining all the land into one parcel, may be required.

We have no other comments regarding this request at this time.