



**CENTURION ENGINEERS, INC.**  
Consulting Engineers and Land Surveyors  
5505 West Franklin Rd. Boise, ID 83705  
Telephone 208.343.3381 | www.centengr.com



To: **Garden City Planning**

Copy: **Jenah Thornborrow  
Betty Gumm  
Hanna Veal  
Elizabeth Parker  
Colin Schmidt  
Kevin Wallis  
James Pavelek  
Troy Vaughn  
Chad Vaughn  
Olesya Durfey**

From: **Joe Canning, PE/PLS**  
Telephone: 208.343.3381  
E-Mail: [jdcanning@centengr.com](mailto:jdcanning@centengr.com)

Date: 22 January 2022

Subject: **Metro Car Wash  
8200 West Chinden Boulevard  
DSRFY2022-0002  
Parcel Number R8191500943  
Planning Review**

Pages: 3

Media: Transmitted via E-mail

On behalf of Garden City, as the city engineer, we have completed our review of the application for the subject project. The application proposes to redevelop the existing car wash site with a new car wash. Our office had previously reviewed this project under file number CUPFY2022-0004

Any approval of the project should be conditioned upon successfully addressing items presented in this review.

***Erosion and Sediment Control***

Prior to performing any grading on the site, the applicant must prepare and have approved by the city an erosion and sediment control plan.

***Ada County Highway District***

Approval of the project by the Ada County Highway District and/or the Idaho Transportation Department will be required.

***Fire District Approval***

Approval of the project by the North Ada County Fire and Rescue District will be required. Should fire flow requirements exceed those available, the land use, improvement of off-site city water lines or other efforts may be necessary to obtain approval of plans.

The review by the District will need to include review of locations of fire hydrants.

***Water and Sewer Connections***

New water and sewer services may be required to serve the project. Said services must be reviewed and approved by the city's Public Works Department.

The applicant is responsible to verify that adequate water system supply is available to provide any fire suppression water needs.

The applicant is responsible to verify that adequate sewer capacity is available and that the existing system depth is adequate to serve the site.

The applicant must contact the city of Boise to ascertain requirements for sanitary sewer service to the property. Garden City does not have a sanitary sewer collection pipeline in the immediate area. We believe connection to the South Boise Interceptor is existing and/or required. Approval for sewer service must be provided by Boise City.

In addition to Boise City's approval, any new sanitary mainline extensions or sewer service connections must also be coordinated, reviewed and approved by Garden City prior to installation. Design and installation is the responsibility of the applicant.

***Site Grading and Drainage Plan***

A site grading and drainage plan will be required to be reviewed and approved by the city.

A storm water design report and a drainage system operation and maintenance manual for handling of storm water prepared by an Idaho licensed design professional will be required. Compliance with the storm water ordinance and policies of the city will be required. Drainage must be maintained on-site.

A site geotechnical report will be required for the design of the on-site storm water system. Said report would identify the depth to seasonal high groundwater, provide a profile of encountered soils and their infiltration rates. The report would also provide a design infiltration rate recommendation for the storm water system. The storm water design must provide for at least three feet of vertical separation between the bottom of the storm water facility and the seasonal high groundwater.

***Storm Water Operation and Management Agreement***

The landowner must enter into an agreement with the city that will be recorded addressing mandatory maintenance of the site's storm water system. The agreement must be fully executed, have conditionally approved plans attached and be recorded by the city with final plan approval.

***Irrigation Facilities***

Any relocation or changes to existing irrigation facilities will require the approval of the entity in control of the facility.

***FEMA Flood Maps***

The applicant must review the original FEMA work maps (not the current adopted maps) as the city has been placed in seclusion. The current maps (June 2020) do not display the possible future risk of the flooding potential of the Boise River. If the lowest floor building elevation is proposed to be below the draft map BFE, a Flood Risk Acknowledgement form will be required from the landowner/developer.

***Legal Parcel of Record***

We note the site consists of a portion of lot or lots within Strawberry Glenn Subdivision and is shown on Record of Survey No, 522. Evidence that the parcel is an original parcel should be provided to the city.

We have no other comments regarding this request at this time.