



Mary May, President  
Alexis Pickering, Vice-President  
Jim D. Hansen, 2<sup>nd</sup> Vice President  
Kent Goldthorpe, Commissioner  
Dave McKinney, Commissioner

November 16, 2022

To: JD Planning & Consulting  
Jorre Delgado  
421 E. Trackstand Lane  
Garden City, Idaho 83714

Subject: GC22-0020/ DSRFY2022-0023  
306 E 46<sup>th</sup> Street  
Silver Bucket Apartments

The applicant is requesting design review approval to allow for the construction of a Residential Multi-Family apartment buildings, consisting of 17 units in 2 duplexes, 2 5-plexes, and a triplex on 0.68 acres.

## A. Findings of Fact

### 1. 46<sup>th</sup> Street

- a. **Existing Conditions:** 46<sup>th</sup> Street is improved with 2-travel lanes, and no curb, gutter or sidewalk abutting the site. There is 50-feet of right-of-way for 46<sup>th</sup> Street (28-feet from centerline).
- b. **Policy:**  
**Local Roadway Policy:** District Policy 7207.2.1 states that the developer is responsible for improving all local street frontages adjacent to the site regardless of whether or not access is taken to all of the adjacent streets.

**Street Section and Right-of-Way Policy:** District Policy 7207.5 states that right-of-way widths for all local streets shall generally not be less than 47-feet wide and that the standard street section shall be 33-feet (back-of-curb to back-of-curb).

**Standard Urban Local Street—33-foot Street Section and Right-of-way Policy:** District Policy 7207.5.2 states that the standard street section shall be 33-feet (back-of-curb to back-of-curb) for developments with any buildable lot that is less than 1 acre in size. This street section shall include curb, gutter, and minimum 5-foot wide concrete sidewalks on both sides and shall typically be constructed within 47-feet of right-of-way.

**Continuation of Streets Policy:** District Policy 7207.2.4 states that an existing street, or a street in an approved preliminary plat, which ends at a boundary of a proposed development shall be extended in that development. The extension shall include provisions for continuation of storm drainage facilities. Benefits of connectivity include but are not limited to the following:

- Reduces vehicle miles traveled.

- Increases pedestrian and bicycle connectivity.
- Increases access for emergency services.
- Reduces need for additional access points to the arterial street system.
- Promotes the efficient delivery of services including trash, mail, and deliveries.
- Promotes appropriate intra-neighborhood traffic circulation to schools, parks, neighborhood commercial centers, transit stops, etc.
- Promotes orderly development.

**Sidewalk Policy:** District Policy 7207.5.7 states that five-foot wide concrete sidewalk is required on both sides of all local street, except those in rural developments with net densities of one dwelling unit per 1.0 acre or less, or in hillside conditions where there is no direct lot frontage, in which case a sidewalk shall be constructed along one side of the street. Some local jurisdictions may require wider sidewalks.

The sidewalk may be placed next to the back-of-curb. Where feasible, a parkway strip at least 8-feet wide between the back-of-curb and the street edge of the sidewalk is recommended to provide increased safety and protection of pedestrians and to allow for the planting of trees in accordance with the District's Tree Planting Policy. If no trees are to be planted in the parkway strip, the applicant may submit a request to the District, with justification, to reduce the width of the parkway strip.

Detached sidewalks are encouraged and should be parallel to the adjacent roadway. Meandering sidewalks are discouraged.

A permanent right-of-way easement shall be provided if public sidewalks are placed outside of the dedicated right-of-way. The easement shall encompass the entire area between the right-of-way line and 2-feet behind the back edge of the sidewalk. Sidewalks shall either be located wholly within the public right-of-way or wholly within an easement.

**Half Street Policy:** District Policy 7207.2.2 required improvements shall consist of pavement widening to one-half the required width, including curb, gutter, and concrete sidewalk (minimum 5-feet), plus 12-feet of additional pavement widening beyond the centerline established for the street to provide an adequate roadway surface, with the pavement crowned at the ultimate centerline. A 3-foot wide gravel shoulder and a borrow ditch sized to accommodate the roadway storm runoff shall be constructed on the unimproved side.

**c. Applicant's Proposal:** The applicant is proposing to construct 46th Street as ½ of 33-foot local street section with pavement widening, curb, gutter, and 6-foot wide attached concrete sidewalk within the existing 50-feet of right-of-way.

**Staff Comments/Recommendations:** The applicant's proposal meets district policy; however, the applicant is required to construct 46th Street as ½ of 33-foot local street section with pavement widening total 16.5-feet from the centerline, curb, gutter, and a minimum 5-foot wide attached concrete sidewalk within the existing 50-feet of right-of-way. If detached sidewalks are required and street trees are desired, then an 8-foot wide planter strip should be provided.

## 2. Driveways – 46th Street

**a. Existing Conditions:** There are two existing unpaved driveways from the site onto 46th Street located:

- 14-foot wide driveway is 408-feet south of Adams Street,

- 25-foot wide driveway is 371-feet south of Adams Street.

**b. Policy:**

**Driveway Location Policy:** District policy 7207.4.1 requires driveways near intersections to be located a minimum of 75-feet (measured centerline-to-centerline) from the nearest local street intersection, and 150-feet from the nearest collector or arterial street intersection.

**Successive Driveways:** District Policy 7207.4.1 states that successive driveways away from an intersection shall have no minimum spacing requirements for access points along a local street, but the District does encourage shared access points where appropriate.

**Driveway Width Policy:** District policy 7207.4.3 states that where vertical curbs are required, residential driveways shall be restricted to a maximum width of 20-feet and may be constructed as curb-cut type driveways.

**Driveway Paving Policy:** Graveled driveways abutting public streets create maintenance problems due to gravel being tracked onto the roadway. In accordance with District policy, 7207.4.3, the applicant should be required to pave the driveway its full width and at least 30-feet into the site beyond the edge of pavement of the roadway.

**Cross Access Easements/Shared Access Policy:** District Policy 7202.4.1 states that cross access utilizes a single vehicular connection that serves two or more adjoining lots or parcels so that the driver does not need to re-enter the public street system.

- c. Applicant's Proposal:** The applicant is proposing to close the two existing driveways located 408 and 371-feet south of Adams Street with pavement widening, curb, gutter, and 6-foot wide attached concrete sidewalk.

The applicant is proposing **to construct a** shared access curb return type driveway from the site onto 46th Street located 377-feet south of Adams Street.

- d. Staff Comments/Recommendations:** The applicant's proposal to close the two existing driveways with curb, gutter, and 6-foot wide attached concrete sidewalk meets District policy and should be approved, as proposed.

Consistent with the District's Driveway Width and Paving policies the applicant should be required to construct a paved shared driveway restricted to a maximum width of 24-foot wide, onto 46th Street located 377-feet south of Adams Street.

### 3. Tree Planters

**Tree Planter Policy:** Tree Planter Policy: The District's Tree Planter Policy prohibits all trees in planters less than 8-feet in width without the installation of root barriers. Class II trees may be allowed in planters with a minimum width of 8-feet, and Class I and Class III trees may be allowed in planters with a minimum width of 10-feet.

### 4. Landscaping

**Landscaping Policy:** A license agreement is required for all landscaping proposed within ACHD right-of-way or easement areas. Trees shall be located no closer than 10-feet from all public storm drain facilities. Landscaping should be designed to eliminate site obstructions in the vision triangle at intersections. District Policy 5104.3.1 requires a 40-

foot vision triangle and a 3-foot height restriction on all landscaping located at an uncontrolled intersection and a 50-foot offset from stop signs. Landscape plans are required with the submittal of civil plans and must meet all District requirements prior to signature of the final plat and/or approval of the civil plans.

## B. Site Specific Conditions of Approval

1. Construct 39th Street as ½ of 33-foot local street section with pavement widening total 16.5-feet from the centerline, curb, gutter, and minimum 5-foot wide attached (or detached) concrete sidewalk within the existing 50-feet of right-of-way abutting the site.
2. Provide a permeant right-of-way easement for detached sidewalks located outside of the dedicated right-of-way.
3. Close the two existing driveways onto 46<sup>th</sup> Street with pavement widening curb, gutter, and sidewalk.
4. Construct a paved shared 24-foot wide driveway onto 46th Street located 377-feet south of Adams Street.
5. A Traffic Impact Fee will be assessed by ACHD and will be due prior to issuance of a building permit. Please contact the ACHD Planner (see below) for information regarding impact fees.
6. Submit civil plans to ACHD Development Services for review and approval. The impact fee assessment will not be released until the civil plans are approved by ACHD.
7. Comply with the Standard Conditions of Approval as noted below.

## C. Traffic Information

### Trip Generation

This development is estimated to generate 105 additional vehicle trips per day (10 existing); and 8 additional vehicle trips per hour in the PM peak hour (1 existing), based on the Institute of Transportation Engineers Trip Generation Manual, 11<sup>th</sup> edition.

### Condition of Area Roadways: Traffic Count is based on Vehicles per hour (VPH)

Roadway	Frontage	Functional Classification	PM Peak Hour Traffic Count	PM Peak Hour Level of Service
Adams Street	0-feet	Collector	149	Better Than "D"
46 <sup>th</sup> Street	100-feet	Local	N/A	N/A

\* Acceptable level of service for a three-lane collector is "D" (530 VPH).

\*\* ACHD does not set level of service thresholds for local roadways.

### Average Daily Traffic Count (VDT): Average daily traffic counts are based on ACHD's most current traffic counts

- The average daily traffic count for Adams Street east of 46<sup>th</sup> Street was 3,715 on June 15, 2022.
- There are no current daily traffic counts for 46<sup>th</sup> Street.

## **D. Attachments**

1. Vicinity Map
2. Site Plan
3. Standard Conditions of Approval
4. Appeal Guidelines

If you have any questions, please feel free to contact me at (208) 387-6171.

Sincerely,

A handwritten signature in cursive script that reads "Renata Ball-Hamilton".


Renata Ball-Hamilton  
Planner  
Development Services

cc: City of Garden City (Garden City Planning), Via Email  
Owner (Kevin Hawk), Via Email

VICINITY MAP



# SITE PLAN





## Standard Conditions of Approval

1. All proposed irrigation facilities shall be located outside of the ACHD right-of-way (including all easements). Any existing irrigation facilities shall be relocated outside of the ACHD right-of-way (including all easements).
2. Private Utilities including sewer or water systems are prohibited from being located within the ACHD right-of-way.
3. In accordance with District policy, 7203.6, the applicant may be required to update any existing non-compliant pedestrian improvements abutting the site to meet current Americans with Disabilities Act (ADA) requirements. The applicant's engineer should provide documentation of ADA compliance to District Development Review staff for review.
4. Replace any existing damaged curb, gutter, and sidewalk and any that may be damaged during the construction of the proposed development. Contact Construction Services at 387-6280 (with file number) for details.
5. A license agreement and compliance with the District's Tree Planter policy is required for all landscaping proposed within ACHD right-of-way or easement areas.
6. All utility relocation costs associated with improving street frontages abutting the site shall be borne by the developer.
7. It is the responsibility of the applicant to verify all existing utilities within the right-of-way. The applicant at no cost to ACHD shall repair existing utilities damaged by the applicant. The applicant shall be required to call DIGLINE (1-811-342-1585) at least two full business days prior to breaking ground within ACHD right-of-way. The applicant shall contact ACHD Traffic Operations 387-6190 in the event any ACHD conduits (spare or filled) are compromised during any phase of construction.
8. Utility street cuts in pavement less than five years old are not allowed unless approved in writing by the District. Contact the District's Utility Coordinator at 387-6258 (with file numbers) for details.
9. All design and construction shall be in accordance with the ACHD Policy Manual, ISPWC Standards and approved supplements, Construction Services procedures and all applicable ACHD Standards unless specifically waived herein. An engineer registered in the State of Idaho shall prepare and certify all improvement plans.
10. Construction, use and property development shall be in conformance with all applicable requirements of ACHD prior to District approval for occupancy.
11. No change in the terms and conditions of this approval shall be valid unless they are in writing and signed by the applicant or the applicant's authorized representative and an authorized representative of ACHD. The burden shall be upon the applicant to obtain written confirmation of any change from ACHD.
12. If the site plan or use should change in the future, ACHD Planning Review will review the site plan and may require additional improvements to the transportation system at that time. Any change in the planned use of the property which is the subject of this application, shall require the applicant to comply with ACHD Policy and Standard Conditions of Approval in place at that time unless a waiver/variance of the requirements or other legal relief is granted by the ACHD Commission.

## Request for Appeal of Staff Decision

1. **Appeal of Staff Decision:** The Commission shall hear and decide appeals by an applicant of the final decision made by the Development Services Manager when it is alleged that the Development Services Manager did not properly apply this section 7101.6, did not consider all of the relevant facts presented, made an error of fact or law, abused discretion or acted arbitrarily and capriciously in the interpretation or enforcement of the ACHD Policy Manual.
  - a. **Filing Fee:** The Commission may, from time to time, set reasonable fees to be charged the applicant for the processing of appeals, to cover administrative costs.
  - b. **Initiation:** An appeal is initiated by the filing of a written notice of appeal with the Secretary and Clerk of the District, which must be filed within ten (10) working days from the date of the decision that is the subject of the appeal. The notice of appeal shall refer to the decision being appealed, identify the appellant by name, address and telephone number and state the grounds for the appeal. The grounds shall include a written summary of the provisions of the policy relevant to the appeal and/or the facts and law relied upon and shall include a written argument in support of the appeal. The Commission shall not consider a notice of appeal that does not comply with the provisions of this subsection.
  - c. **Time to Reply:** The Development Services Manager shall have ten (10) working days from the date of the filing of the notice of appeal to reply to the notice of the appeal, and may during such time meet with the appellant to discuss the matter, and may also consider and/or modify the decision that is being appealed. A copy of the reply and any modifications to the decision being appealed will be provided to the appellant prior to the Commission hearing on the appeal.
  - d. **Notice of Hearing:** Unless otherwise agreed to by the appellant, the hearing of the appeal will be noticed and scheduled on the Commission agenda at a regular meeting to be held within thirty (30) days following the delivery to the appellant of the Development Services Manager's reply to the notice of appeal. A copy of the decision being appealed, the notice of appeal and the reply shall be delivered to the Commission at least one (1) week prior to the hearing.
  - e. **Action by Commission:** Following the hearing, the Commission shall either affirm or reverse, in whole or part, or otherwise modify, amend, or supplement the decision being appealed, as such action is adequately supported by the law and evidence presented at the hearing.