

**From:** [Jenah Thornborrow](#)  
**To:** [Rebecca Kent](#)  
**Cc:** [Hanna Veal](#); [Mark Jones](#)  
**Subject:** Design Review  
**Date:** Monday, December 5, 2022 10:20:48 AM  
**Attachments:** [image002.png](#)  
[image003.png](#)  
[image004.png](#)  
[image005.png](#)

---

Rebecca,

The Design Review does not see an issue with you proceeding with the below prior to approval:

- 1) Siding - painted composite shiplap and cedar siding as shown in the submitted elevations and renderings.
- 2) Railing - wrought iron vertical railing with spindles spaced 4" o.c. 42" high per code. (We originally wanted horizontal railing but to prevent a "ladder effect" we switched to vertical.)
- 3) Windows - replace windows with new aluminum double glazed windows.
- 4) Signage - paint the name of the building on the side of the building. Use the building as a sign, as shown in the submitted rendering.

Sincerely,



**Jenah E. Thornborrow**

*Director*

Development Services Department, **City of Garden City**

p: 208-472-2921

a: 6015 Glenwood Street, Garden City, ID 83714

w: <https://gardencityidaho.org/>

