

**Garden City Design Review
Application Review**

DSRFY2022-0030

Exterior Improvements to 3433 W. Chinden Blvd

Review Date: 10.12.22

Applicant Meeting Date: 10.17.22

Review Comments:

1. Provide location & screening for new heat pumps / condenser units that will be needed for the new mini-split systems installed in each of the rooms.
2. Confirm how trash is to be handled and screening as may be required.

Reviewer Signature:



Brett G. Labrie, Architect