

Jeffrey A. Ramey
Commissioner/Chair

J. Todd Bunderson
Commissioner

Jeffrey A. Souza
Commissioner



Shelley Vaughan
*District
Administrator*

November 7, 2022

Garden City Development Services

Re: SUBFY2022-0008 401 E 52nd St – Chandlers Place

This is a request for a 12 unit planned unit development of townhomes.

North Ada County Fire & Rescue District has reviewed and can approve the application subject to compliance with no further comment.

General Requirement:

Fire Department required fire hydrants, access, and street identification shall be installed prior to construction or storage of combustible materials on site. Provisions may be made for temporary access and identification measures.

Specific building construction requirements of the International Building Code, International Fire Code and NACFR Rules will apply. However, these provisions are best addressed by a licensed Architect at time of building permit application.

Regards,

Mike Bisagno

Mike Bisagno
Division Chief – Fire Marshal
Boise Fire Department