

Jeff Ramey
Commissioner/Chairman

J. Todd Bunderson
Commissioner

Jeff Souza
Commissioner



Shelley Vaughan
District
Administrator

October 21, 2024

Garden City Development Services

Re: SUBFY2024-0006 219 E 44th St

This is a request for a Preliminary/Final Plat for a ten-lot residential subdivision.

North Ada County Fire & Rescue District has reviewed and can approve the application subject to compliance with all the following code requirements and conditions of approval. The following are the comments from the Preliminary Plat application and still apply.

Comments:

1. Fire hydrants, capable of producing the required fire flow, shall be located so that no part of the structure is more than 600-feet from the hydrant. (IFC 507.3, IFC B105.2, IFC C105). **Proposed hydrant location at East end of lane complies with this requirement.**
2. Fire apparatus access roads shall extend to within 150 feet of all portions of the exterior walls of the first story of a building measured by an approved route around the exterior of the building or facility. (IFC 503.1.1)
3. Fire apparatus access roads shall have an unobstructed width of not less than 20 feet and an unobstructed vertical clearance of not less than 13 feet 6 inches. (IFC 503.2.1)
4. Structures greater than 30-feet in height will require aerial fire access roadways. These roadways shall be a minimum of 26-feet in width and located at least 15-feet but no more than 30-feet from the building. (IFC D105) **The common drive is shown to be 26 feet wide to afford the required fire department aerial access.**
5. The minimum outside turning radius of a fire apparatus access road shall be 48 feet. The minimum inside turning radius shall be 28 feet. (BCC 5-12-29, IFC 503.2.4)
6. Fire apparatus access roads shall have an approved driving surface of asphalt, concrete or other approved driving surface and can support the imposed load of fire apparatus weighing at least 75,000 pounds. Documentation maybe requested at final inspection that the road surface meets this standard. (IFC D102.1)
7. For streets having a width less than 33 feet back of curb to back of curb parking shall be restricted on one side, for streets having a width less than 27 feet back of curb to back of curb parking shall be restricted on both sides, and all portions of the turn-around. A note on the face of the final plat is required noting the parking

restriction prior to signing of the final plat by the City Engineer. In addition, No Parking signs shall be installed in accordance with the requirements of the IFC. (IFC 503.8) **Parking will be not be allowed along the common drive. Parking will only be allowed in the individual driveways. Signage indicating this will need to be posted at the entrance to this subdivision.**

General Requirement:

Fire Department required fire hydrants, access, and street identification shall be installed prior to construction or storage of combustible materials on site. Provisions may be made for temporary access and identification measures.

Specific building construction requirements of the International Building Code, International Fire Code and NACFR Rules will apply. However, these provisions are best addressed by a licensed Architect at time of building permit application.

Regards,

Mike Bisagno

Mike Bisagno
Division Chief – Fire Marshal
Boise Fire Department

